

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 2101816

Port Orford-Langlois 2CJ School Distict	Project: General	Date Reported: 11/01/22
PO Box 8	Project #: Port Orford-Langlois / Lead Water	Date Received: 10/18/22 14:00
Port Orford, OR 97465	Test	Sampled By: Steve Perkins
	Client Contact: Attn: Steve Perkins	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
2101816-01	Sample Location: 1st Fountain Library Wing #1									
	Lead (⊘)	1030	ND	ppb	1.0	15	10/18/22 07:28	10/20/22	DST	
2101816-02	Sample Location: 2nd Fountain Library Wing #2									
	Lead (⊘)	1030	ND	ppb	1.0	15	10/18/22 07:29	10/20/22	DST	
2101816-03	Sample Location: Science Lab Sink #3									
	Lead (⊘)	1030	6.9	ppb	1.0	15	10/18/22 07:30	10/20/22	DST	
2101816-04	Sample Location: Lab Station 1, Lt. Faucet #4									
	Lead (⊘)	1030	3.4	ppb	1.0	15	10/18/22 07:31	10/20/22	DST	
2101816-05	Sample Location: Lab Station 1, Rt. Faucet #5									
	Lead (⊘)	1030	9.9	ppb	1.0	15	10/18/22 07:31	10/20/22	DST	
2101816-06	Sample Location: Lab Station 3, Lt. Faucet #6									
	Lead (⊘)	1030	3.5	ppb	1.0	15	10/18/22 07:32	10/20/22	DST	
2101816-07	Sample Location: Wellness Center, Main Sink #7									
	Lead (⊘)	1030	3.4	ppb	1.0	15	10/18/22 07:33	10/20/22	DST	
2101816-08	Sample Location: Wellness Center Ob Room Sink #8									
	Lead (⊘)	1030	12.3	ppb	1.0	15	10/18/22 07:33	10/20/22	DST	
2101816-09	Sample Location: Staff Rm, 1st Faucet #9									
	Lead (⊘)	1030	16.6	ppb	1.0	15	10/18/22 07:34	10/20/22	DST	
2101816-10	Sample Location: Staff Rm, 2nd Faucet #10									
	Lead (⊘)	1030	4.5	ppb	1.0	15	10/18/22 07:35	10/20/22	DST	
2101816-11	Sample Location: Girls 2nd BR, Lt. Sink Main Hall #11									
	Lead (⊘)	1030	4.2	ppb	1.0	15	10/18/22 07:37	10/20/22	DST	
2101816-12	Sample Location: 2nd GBR, Rt. Sink Main Hall #12									
	Lead (⊘)	1030	1.1	ppb	1.0	15	10/18/22 07:37	10/20/22	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 2101816

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
2101816-13	Sample Location: 2nd BBR Main Hall, Lt. Sink #13									
Lead (⊘)		1030	ND	ppb	1.0	15	10/18/22 07:39	10/20/22	DST	
2101816-14	Sample Location: 2nd BBR Main Hall, Rt. Sink #14									
Lead (⊘)		1030	ND	ppb	1.0	15	10/18/22 07:39	10/20/22	DST	
2101816-15	Sample Location: Cafeteria Sink #15									
Lead (⊘)		1030	18.3	ppb	1.0	15	10/18/22 07:41	10/20/22	DST	
2101816-16	Sample Location: Cafeteria Wash Basin #16									
Lead (⊘)		1030	22.8	ppb	1.0	15	10/18/22 07:41	10/20/22	DST	
2101816-17	Sample Location: Referee's Room Sink #17									
Lead (⊘)		1030	3.2	ppb	1.0	15	10/18/22 07:45	10/20/22	DST	
2101816-18	Sample Location: Music Room Fountain #18									
Lead (⊘)		1030	6.0	ppb	1.0	15	10/18/22 07:47	10/20/22	DST	
2101816-19	Sample Location: Rm 2C Faucet #19									
Lead (⊘)		1030	45.9	ppb	1.0	15	10/18/22 07:50	10/20/22	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 2101816

Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3021501

Port Orford-Langlois 2CJ School Distict PO Box 8 Port Orford, OR 97465	Project: General Project #: Port Orford School District Client Contact: Attn: Steve Perkins	Date Reported: 02/20/23 Date Received: 02/15/23 08:53 Sampled By: Steve Perkins
--	---	---

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
3021501-01	Sample Location: PHS Staff Room 1st Faucet									
	Lead (¢)	1030	ND	ppb	1.0	15	02/13/23 12:00	02/16/23	DST	
3021501-02	Sample Location: PHS Room 2C Faucet									
	Lead (¢)	1030	1.9	ppb	1.0	15	02/13/23 12:01	02/16/23	DST	
3021501-03	Sample Location: PHS Cafeteria Sink									
	Lead (¢)	1030	ND	ppb	1.0	15	02/13/23 12:02	02/16/23	DST	
3021501-04	Sample Location: PHS Cafeteria Wash Basin									
	Lead (¢)	1030	ND	ppb	1.0	15	02/13/23 12:02	02/16/23	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 3021501

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager